



Door Access / Hub Gate Hub



^ Overview

Dimensions

175 x 126 x 26 mm
(6.9 x 5 x 1")

UniFi Application Suite

└ Access

✓

Supported Doors

1 gate, 1 side door

Maximum User Count

6,000

Input Terminals

(1) Gate exit request
(1) Gate position
(1) Side door exit request
(1) Side door position
(1) Emergency

Power Method

PoE++
UL 294 Power-limited Class 2 PSU
UL 60950-1/62368-1 LPS/PS2 PSU

NDAA Compliant

✓

UL 294 Level

Destructive attack: Level I
Line security: Level I
Endurance: Level I
Standby power: Level I

^ Mechanical

Weight	460 g (1 lb)
Enclosure Material	Polycarbonate
Mounting	DIN-rail (Included)

^ Hardware

Digital Input	Gate exit request, gate position, side door exit request, side door position, emergency
Dry Output Relay	(2) Operator: rated 30V DC, up to 1A (1) Aux: rated 30V DC, up to 1A
Powered Output Relay	Side door lock: 12V DC, up to 1A
Indoor and Outdoor Use	Indoor only: device itself Outdoor: with waterproof junction box
Ambient Operating Temperature	-30 to 60° C (-22 to 140° F)
Ambient Operating Humidity	5 to 90% noncondensing
Networking Interface	(5) 10/100/1000 Base-T
PoE Interface	(1) PoE++ input, 50V DC, 1A (4) PoE+ outputs, 50V DC, 30W per port (Max 55W aggregated)
Max. Power Consumption	22W (Without PoE output) 60W (With PoE output)
LEDs	W/B Learn More
Buttons	(1) Factory-reset

Recommend Max. Cable Length

UA-Lock-Electric (400mA)	24 AWG length: 25 m (82 ft) 22 AWG length: 42 m (138 ft) 20 AWG length: 66 m (217 ft) 18 UACC-Cable-DoorLockRelay length: 100 m (328 ft)
UA-Lock-Magnetic-540kg (500mA)	24 AWG length: 20 m (66 ft) 22 AWG length: 32 m (105 ft) 20 AWG length: 51 m (167 ft) 18 UACC-Cable-DoorLockRelay length: 80 m (262 ft)
UA-Lock-Magnetic-270kg (800mA)	24 AWG length: 12 m (29 ft) 22 AWG length: 20 m (66 ft) 20 AWG length: 30 m (98 ft) 18 UACC-Cable-DoorLockRelay length: 46 m (151 ft)
Other locks (1A)	24 AWG length: 9 m (30 ft) 22 AWG length: 15 m (49 ft) 20 AWG length: 24 m (79 ft) 18 UACC-Cable-DoorLockRelay length: 36 m (118 ft)

PoE Cabling Requirements

Cat 5e cabling is the minimum performance category recommended. The performance category utilized should match the transmission speed required at the installation site.
The minimal conductor gauge permitted to connect between the PSE or power injector and the PD shall be 26 AWG (0.13 mm²) for patch cords; 24 AWG (0.21 mm²) for horizontal or riser cable.

UL 294 Statement

Compliance with IEEE 802.3 specifications was not verified as part of UL 294.
The equipment is intended to comply with the section of the National Electrical Code, ANSI/NFPA 70, Article 725.121, Power Sources for Class 2 and Class 3 Circuits.

CAN/ULC-60839-11-1 Grade

Grade assignment: I

Certifications

CE, FCC, IC, UL 294, CAN/ULC-60839-11-1

Document number, and issue date and/or revision level

UA-Hub-Gate, V01

^ **Software**

Management Application

Access

Software Information

The software version can be checked at <https://unifi.ui.com>

